



**NATIONAL INSTITUTE FOR RESEARCH-DEVELOPMENT AND
TESTING IN ELECTRICAL ENGINEERING
I C M E T - CRAIOVA**

**TYPE TEST REPORT
No. 13464 / 28.11.2019**

We, hereby, verify that the under mentioned electrical product submitted to the tests in our laboratory, in July 2019, is in compliance with the related clauses and sub-clauses of standard IEC 62271-100 as mentioned in the attached TEST REPORT.

Name of product	24 kV / 1250 A / 25 kA Vacuum Circuit Breaker
Manufacturer	JSC "PO ELTECHNICA"
	Vacuum Circuit Breaker
Model/Type	VF24-S-20-25-B-1250-00.00 Y3
Serial Number	13413/2019
Technical characteristics established by producer	
Rated voltage	24 kV
Rated current	1250 A
Number of poles	3
Rated frequency (fr)	50 Hz
Rated operating sequence	O-0.3s-CO-3min-CO
Short-time withstand current	25 kA
Peak withstand current	63 kA
Rated duration of short-circuit	3 s
Short-circuit making current	25 kA
Short-circuit breaking current	63 kA
Class	M2-C2

The product passed successfully the following type tests:

➤ **24 kV / 1250 A / 25 kA Three-poles Vacuum Circuit Breaker acc. to IEC 62271-100**

No	Test type / IEC clause	Test result	Test Report No.
1.	Dielectric tests	Passed the test	46808
1.1	Lightning impulse voltage test , cl. 6.2.6.2		
1.2	Power frequency voltage test - dry, cl. 6.2.6.1		
1.3	Dielectric test on auxiliary circuit, cl. 6.2.10		
2	Measurement of the resistance of the main circuit, cl. 6.4	Passed the test	13034
3	Temperature rise test, cl. 6.5		
4	Short-time withstand current and peak withstand current test ,cl. 6.6		

No	Test type / IEC clause	Test result	Test Report No.
5	Mechanical endurance on circuit breaker, cl. 6.101.2.4	Passed the test	13035
6	Basic short-circuit test duties T10, T30, T60, T 100s in cycles: O-0.3s-CO-3min-CO T100a in cycles: 0-3 min-0-3min-0, cl.6.106	Passed the test	13034
7	Single phase and double earth fault test, cl 6.108 in cycle O		

NOTE: The test parameters can be found in the test reports listed above.

General Manager
PhD. Lucian Pricina



**Technical Manager of
Low and High Voltage Laboratory**
Dipl. Eng. Ion BURCIU

**Technical Manager of
High Power Laboratory**
Phys. Daniel TRUTA

ICMET Laboratories are accredited by RENAR – member of ILAC (Certificates No. LI1036 and LI004) to perform the tests listed in this certificate. This report shall not be reproduced, except in its entirety, without the written approval of ICMET Craiova.

ICMET Craiova
www.icmet.ro

B-dul Decebal 118A
Craiova, 200746

Phone: + 40 351 404 888
Fax: + 40 351 404 890